

SUTTER COUNTY FIRE CODE REQUIRES COMPLIANCE WITH THOSE ITEMS INDICATED BELOW:

1. ELECTRICAL:

- ☐ a. Discontinue use of extension cords in lieu of permanent wiring (CFC 8506.1)
- ☐ b. Remove extension cords running through openings or attached in series (CFC 8506.1)
- ☐ c. Remove extension cords placed under rugs, furniture or where subject to damage (CFC 8506.3)
- ☐ d. Provide junction box covers, switch plates and duplex plates (CEC 410.12)
- ☐ e. Electrical panel and equipment shall have a minimum of 30 inches working space (CFC 8509.2)

2. EXITS:

- ☐ a. Remove all other locks or latches from exit doors (CFC 1207.3)
- ☐ b. Remove obstructions from exits, aisles, corridors and stairways (CFC 1203)
- ☐ c. Unlock all exit doors during business hours and post signage "This door to remain unlocked during business hours" (CFC 1207.3)
- ☐ d. Means of egress illumination shall be provided and maintained (CFC 1211.1)

3. FIRE ALARM SYSTEMS:

- ☐ a. Maintain fire alarm systems in operable condition, test quarterly and maintain records of testing (CFC 1001.5.2)

4. FIRE DOORS:

- ☐ a. Remove obstruction(s) and alterations to fire doors that are automatic or self-closing type (CFC 1111.2.1)
- ☐ b. Doors not to be blocked open, except with approved devices (magnetic door holders) (CFC 1111.2.2)
- ☐ c. Keep attic access and scuttle openings closed (CFC 1111.2.1)

5. FIRE EXTINGUISHERS:

- ☐ a. Provide _____ extinguisher(s) of a _____ minimum rating (CFC Standard 10 -1)
- ☐ b. Mount extinguishers where readily available and visible (CFC Standard 10 -1)
- ☐ c. Post signs indicating location where extinguishers are not readily visible (CFC Standard 10 -1)
- ☐ d. Service and tag (By State License) each extinguisher annually and after use (CFC 1001.5.1)

6. FIRE PROTECTION INSTALLATIONS:

- ☐ a. Maintain access to, and operation of standpipes, fire hose, sprinkler, control valves and hydrants (CFC 1001.7.1)
- ☐ b. Inspect and test sprinkler system quarterly and maintain records (CFC 1001.5.2)
- ☐ c. Identify sprinkler valves and secure in open position (CFC 1001.5.2)
- ☐ d. Provide spare sprinklers (6 minimum) and sprinkler wrench (CFC 1001.5.2)
- ☐ e. Inspect and service semi-annually and after use, all hood and duct extinguishing systems over cooking equipment..... (CFC 1005.2.8)
- ☐ f. remove decorations or other attachments from sprinkler system (CFC 1001.5.2)
- ☐ g. Replace damaged, corroded or painted sprinkler heads (CFC 1001.5.2)

7. HEAT PRODUCING APPLIANCES:

- ☐ a. Remove combustibles and storage from heater area or room (CFC 1107.1)
- ☐ b. Provide clearance between heat producing appliances and combustible material (CFC 1107.1)

8. HOUSEKEEPING (INTERIOR):

- ☐ a. Remove or store rubbish, waste material and oily rags in closed metal containers (CFC 1103)
- ☐ b. Clean grease filters and hood duct systems over cooking appliances (CFC 1005.2.8)

9. RUBBISH (OUTSIDE ACCUMULATION):

- ☐ a. Remove combustible vegetation when determined to be a fire hazard (CFC 1103.2.4)

10. STORAGE:

- ☐ a. Arrange storage in an orderly manner and provide for exiting and Fire Department access (CFC 1203)
- ☐ b. Remove storage 18 inches below sprinklers (36 inches for storage piled over 12 feet high) (CFC 1103.3.2.2)
- ☐ c. Reduce storage height to a least 2 feet below ceiling (CFC 1103.3.2.2)
- ☐ d. Secure and identify compressed gas cylinders with name of product (CFC 7401.6.1)

11. GAS:

- ☐ a. Gas shut off to be installed within three (3) feet of the appliance and readily accessible (CPC 1211.18)
- ☐ b. Provide protection for gas meter (CFC 1106)

12. CONSTRUCTION:

- ☐ a. Repair holes in ceiling and / or walls to restore fire resistive integrity (CFC 1111.1)

ADDITIONAL REQUIREMENTS AND/OR REQUIREMENTS: _____

I HAVE RECEIVED A COPY OF THIS FIRE SAFETY NOTICE _____ DATE ____/____/____

Signature

RE-INSPECTION BY _____ DATE ____/____/____

☐ VIOLATIONS CORRECTED (date) ____/____/____

☐ REFER TO COUNTY FIRE CHIEF (date) ____/____/____