SUTTER COUNTY FIRE SAFETY NOTICE

☐ LIVE OAK (530)695-3522	☐ SUTTER (530)755-0266 ☐ PLEASANT GROVE (916)655-3937	☐ OSWALD TUDOR (530)673-2804
☐ EAST NICOLAUS (530)656-2261		
DATE/ INSPECTED BY RE-INSPECTION DATE/		
Contact Inspecting Officer for all inquiries or additional information.		
BUSINESS NAME	ADDRESS MAN	AGER OCCY, PHONE
BUSINESS OWNER	ADDRESS	PHONE
PROPERTY OWNER	ADDRESS	PHONE
SUTTER COUNTY FIRE CODE REQUIRES COMPLIANCE WITH THOSE ITEMS INDICATED BELOW:		
 1. ELECTRICAL: □a. Discontinue use of extension cords in lieu of permanent wiring. (CFC 605.5) □b. Remove extension cords placed under rugs, furniture or where subject to damage. (CFC 605.5) □c. Provide approved covers for all switch and electrical outlet boxes. (CFC (605.6) □d. Multiplug adapters, unfused plug strips or any other devise not complying with the California Electrical Code shall be prohibited. (CFC 605.4) □e. Electrical service equipment shall have a minimum of 30 inches width, 36 inches depth, 78 inches height, of working space. (CFC 605.3, Page 101) 		
2. EXITS □a. Remove manually operated flush bolts or surface bolts from exit doors. (CFC 1008.1.9.4) □b. Remove obstructions from exits, maintain egress system. (CFC 1003.1) □c. Exit and exit access doors shall be marked by an approved exit sign. (CFC 1011.1) □d. Means of egress illumination shall be provided and maintained. (CFC 1011.3, Page 215)		
3. FIRE ALARM SYSTEMS □a. Maintain fire alarm systems in operable condition, test, and maintain a written record. (CFC 907.8.5, Page 175)		
 4. FIRE-RESISTANCE-RATED CONSTRUCTION □ a. Maintain fire-resistant-rated construction (including walls, fire stops, floors). (CFC 703.1) □ b. Fire doors shall not be blocked or obstructed or otherwise made inoperable. (CFC 703.2) 		
5. FIRE EXTINGUISHERS a. Provide extinguisher(s) of a minimum rating. (CFC 906.1) b. Mount extinguishers where readily available and visible. (CFC 906.5) c. Post signs indicating location where extinguishers are not readily visible. (CFC 906.6) d. Service and tag (By State License) each extinguisher annually and after use. (CFC 906.2, Chapter 3 Title 19). e. Provide Class K portable fire extinguisher for deep fat fryers. (CFC 904.11.5.2) f. Provide extinguisher of a minimum rating on Powered Industrial Trucks (Fork Lift). (CFC 906.1)		
6. FIRE PROTECTION SYSTEMS □a. Fire protection systems shall be inspected, tested and maintained. (CFC 901.6.1) □b. Records of systems inspections, tests and maintenance shall be maintained on the premises for three years. (CFC 901.6.2) □c. Removal or tampering with fire hydrants, alarm systems or fire suppression systems is prohibited. (CFC 901.8) □d. Inspect and test semi-annually and after use, commercial hood and duct systems. (CFC 904.11.6.2, Page 148)		
7. HEAT PRODUCING APPLIANCES □a. Combustible material shall not be stored in boiler rooms, mechanical rooms or electric equipment rooms. (CFC 315.3.3, Page 74) □b. Provide clearance between ignition sources, flame producing devices and combustible materials. (CFC 305.1)		
8. HOUSE KEEPING INTERIOR □a. Remove or store hot ashes, oily materials subject to spontaneous ignition in non-combustible receptacle. (CFC 305.2) □b. Combustible waste material creating a fire hazard shall not be allowed to accumulate in buildings or structures or upon premises (CFC 304.1)		
9. VEGETATION □a. Remove combustible vegetation when determined to be a fire hazard. (CFC 304.1.2)		
10. STORAGE □a. Arrange storage in an orderly manner and provide for exiting. (CFC 315.3.2, Page 74) □b. Storage shall be maintained 2 feet below ceiling in non-sprinklered buildings. (CFC 315.3.1, Page 74) □c. Storage shall be maintained 18 inches below sprinklers. (CFC 315.3.1, Page 74) □d. Compressed gas containers, cylinders and tanks shall be secured to prevent falling. (CFC 5303.5.3, Page 400)		
 11. GAS □a. Gas meters and piping shall be provided with vehicle impact protection. (CFC 603.9) □b. Discontinue operation of unsafe heating appliances, stoves, or any other heat-producing device. (CFC 603.7) 		
ADDITIONAL REQUIREMENTS:		
LUAVE DECEMEN A CORV OF THE FIRE	E SAFETY NOTICE	DATE
RE-INSPECTION BY DATE DATE VIOLATIONS CORRECTED (DATE)		

2013 CALIFORNIA FIRE, ELECTRICAL AND PLUMBING CODES
Original (white copy) Fire Department – Yellow Copy to Occupant

01/14